

Declaration of Conformity according to EN 13141-7:2004 / EN308

Technical Sciences
Laan van Westenenk 501
7334 DT Apeldoorn
Postbus 342
7300 AH Apeldoorn

www.tno.nl

T +31 88 866 22 12
F +31 88 866 22 48
infodesk@tno.nl

TNO 2012 M10384A

Determination of the energetic efficiency
of the energy recovery appliance
“Renovent Sky 300”
Test report in accordance with
EN 13141-7:2004 / EN308

| | |
|----------------|---|
| Date | May 2013 |
| Author(s) | H.A.J. Hammink |
| Sponsor | Brink Climate Systems BV R.D. Bügelstraat 3 7951 DA Staphorst |
| Project number | 060.01122 |
| Keywords | heat recovery efficiency |

All rights reserved.

No part of this publication may be reproduced and/or published by print, photoprint, microfilm or any other means without the previous written consent of TNO.

In case this report was drafted on instructions, the rights and obligations of contracting parties are subject to either the General Terms and Conditions for commissions to TNO, or the relevant agreement concluded between the contracting parties. Submitting the report for inspection to parties who have a direct interest is permitted.

© 2013 TNO

Declaration of Conformity according to EN 13141-7:2004 / EN308

On behalf of Brink Climate Systems B.V., located in Staphorst, the Netherlands, the determination of the energetic efficiency was carried out by TNO Technical Sciences in Apeldoorn, the Netherlands.

Testing was performed according to:

- EN13141-7:2004 Performance testing of mechanical supply- and exhaust air ventilation units for single-family dwellings
- EN308, heat exchangers – Test procedures for establishing performance of air to air and flue gases heat recovery devices.

Key data for the tested unit:

| | |
|-----------------------|----------------------------|
| Manufacturer: | Brink Climate Systems B.V. |
| Type | Renovent Sky 300 |
| Serial number: | 422004121601 |
| Year of construction: | 2012 |
| CE approval: | Yes |
| Max. air flow | 300 m ³ /h |

Results for the energetic efficiency:

| Air flow [m ³ /h] | Corrected η_{temp} | Power [W] | Voltage [V] | Current [A] | Power factor [-] |
|---------------------------------|----------------------------|--------------|----------------|----------------|---------------------|
| 50 | 95.9 | 12.8 | 230.4 | 0.15 | 0.37 |
| 175 | 86.3 | 31.5 | 230.4 | 0.37 | 0.37 |
| 300 | 81.6 | 109.4 | 230.3 | 0.99 | 0.48 |

Date : 1 May 2013



Place : Apeldoorn

Signed :

Drs. P.M. van Hoorik

Research Manager Energy and Comfort Systems

Measurement results, leak tightness classification, fan characteristics and the functioning of the energy recovery appliance at low temperatures are given in short report TNO 2012 M10384, July 2012.