Tehniline leht

Flair 325
Soojustagastusseade
Eesti

Air for Life

Üldine

Flair 325 ja Flair 325 Plus on elamute ventilatsioonisüsteemidesse mõeldud soojustagastusseade.

Omadused:

- Maksimaalne vooluhulk 325 m^3/h
- Efektiivne plastist soojusvaheti
- Filtrid ISO-jämedusega 60%
- Elektriline eelsoojendusmoodul
- Automaatne möödavooluklapp
- Puuteekraan
- Reguleeritav õhukogus
- Filtrinäidik seadmel endal ja võimalik lisada filtrinäidik pöördlülitile
- Automaatne külmumiskaitse koos eelsoojendusmooduliga
- Vaikne
- Vooluhulga pidevjuhtimine

Flair 325 on saadaval kahe tüübina:

- **„Flair 325“**
- **„Flair 325 Plus“**

Võrreldes tavalise tüübiga Flair 325 on tüübil Flair 325 Plus täiendav PCB (trükkplaat), mis pakub rohkem funktsioone/ühendusvõimalusi (→ Ühendused ja mõõtmed lk 4).
Käesolevas paigaldusjuhendis käsitletakse nii tüüpi Flair 325 kui ka tüüpi Flair 325 Plus.

Flair 325 ja Flair 325 Plus on saadaval **vasakukäelise** ja **paremakäelise** versioonina; vasakukäelisest versioonist ei saa teha paremakäelist ega vastupidi.
Õiged ühendustorud ja mõõtmed leiate siit (jaotisest Ühendused ja mõõtmed lk 4).

Täiendav PCB seevastu on võimalik seadmele hiljem paigaldada.

Seadmega on ühendatud 230 V toitekaabel.

Tehniline teave

Tehniline teave

Flair 325 (Plus)										
Toitepinge [V/Hz]	230 V / 50 Hz									
Mõõtmed (l × k × s) [mm]	750 × 650 × 560									
Õhukanali läbimõõt [mm]	ø160									
Kondensvee toru välisläbimõõt [mm]	ø32									
Kaal [kg]	37									
Filtriklass	ISO jämedus 60% (valikuliselt sissepuhkefilter ISO ePM1.0 50%)									
Ventilaatori seaded (tehaseseaded)	0		1		2		3		max	
Tehaseseade [m³/h]	50		100		150		250		325	
Kanalite lubatav vasturõhk [Pa]	2	6	9	24	21	53	59	148	100	250
Nimivõimsus (v.a eelsoojendi) [W]	6,1	6,6	7,9	10,3	15,1	21,0	46,6	69,1	87,5	144,5
Nimivoolutugevus (v.a eelsoojendi) [A]	0,08	0,08	0,09	0,11	0,15	0,21	0,41	0,59	0,73	1,07
Max voolutugevus (eelsoojendi sisse lülitatud) [A]	6									
Cos φ	0,341	0,343	0,389	0,394	0,430	0,439	0,492	0,507	0,521	0,542
Müravõimsus										
Ventilatsiooniõhu vooluhulk [m³/h]				100	150	150	200	200	250	325
Müravõimsustase Lw(A)	Staatiline rõhk [Pa]			25	25	50	50	100	150	150
	Korpusest kiirguv [dB(A)]			27	34	35	40	41	46	51
	Elamust väljuv kanal [db(A)]			32	40	38	46	44	49	55
	Elamusse sisenev kanal [db(A)]			44	49	51	55	57	62	69

*) Kanalimüra koos lõppkorrektsiooniga
Praktikas mõõdetav väärtus võib mõõtmistulemuste tolerantsi tõttu erineda kuni 1dB(A) võrra.

Kanalite vasturõhk [Pa]



Vooluhulk [m³/h]

Märkus:
Ringiga ümbritsetud väärtus on ühe ventilaatori võimsus (vattides).

Ühendused ja mõõtmed

Seade Flair on saadaval vasaku- ja paremakäelises versioonis. Vasakukäelise versiooni puhul on „soojad" ühendused (elamust väljuv 3 ja elamusse suunduv 1) seadme vasakul küljel ning kondensvee toru paigaldatakse seadme all olevale parempoolsele avale. Paremakäelise versiooni puhul on „soojad" ühendused (1 ja 3) seadme paremal küljel.

Vasakukäeline versioon





Kõik mõõtmed on millimeetrites. Kõigi õhukanalite läbimõõt on 160 mm

1	Elamusse	
2	Õue	
3	Elamust	
4	Õuest	
5	Elektriühendused	
6	Siphon connection	
7	Väljapuhkefilter	
8	Sissepuhkefilter	
9	Kinnitus	

Paremakäeline versioon



Kõik mõõtmed on millimeetrites. Kõigi õhukanalite läbimõõt on 160 mm

1	Elamusse	
2	Õue	
3	Elamust	
4	Õuest	
5	Elektriühendused	
6	Siphon connection	
7	Väljapuhkefilter	
8	Sissepuhkefilter	
9	Kinnitus	

Service esemed

Koostejoonis

Varuosade tellimisel märkige tellimusse lisaks varuosa numbrile (vt koostejoonist) soojustagastusseadme tüüp, seerianumber, valmistamisaasta ja varuosa nimi.

Tähelepanu! Osa tüüp, seerianumber ja valmistamisaasta on kirjas seadme plastist esipaneeli taga oleval andmesildil.

Näide	
Seadme tüüp	Flair 325
Seerianumber	430000184701
Valmistamisaasta	2019
Varuosa	Ventilaator
Varuosa kood	532759
Arv	1

Varuosad



Nr	Varuosa kirjeldus	Varuosa kood
1	Esipaneeli täielik	532763
2	Filtrid (2 tk) ISO-jämedusega 60%	532716
3	Soojusvaheti	532754
4	Ventilaator (1 tk)	532759
5	Möödavooluklapi komplekt koos mootoriga	532760
6	Ekraani PCB UBP-2	532752
7	Standard-PCB UWA2-B	532750
8	Plus-PCB UWA2-E (ainult Plus-versiooni puhul)	532751
9	Toitepistik ja -kaabel, 230 V *	532756
10	Sisemine eelsoojendi ülekuumenemiskaitsega	532761
11	Temperatuuriandur NTC 10K	531775
12	Kondensvee toru	532762
13	Kaablikomplekt	532767

* Toitekaablil on eriline pistik. Kui toitekaabel on vaja välja vahetada, tellige kindlasti uus Brink.
Ohtlike olukordade vältimiseks tohib kahjustatud toitekaabli välja vahetada ainult kvalifitseeritud elektrik!

Sertifikaate

Vastavusdeklaratsioon

Vastavusdeklaratsioon

Tootja:	**Brink Climate Systems B.V.**
Aadress:	**Postbus 11** **NL-7950 AA, Staphorst, The Netherlands**
Toode:	**Soojustagasti tüüp:** **Flair 325** **Flair 325 Plus**

Ülal kirjeldatud toode vastab järgmiste direktiivide nõuetele:

- 2014/35/EL (madalpingedirektiiv)
- 2014/30/EL (EMÜ direktiiv)
- RoHS 2011/65/EL (ohtlike ainete direktiiv)
- 2009/125/EC (1253/1254 EL (EL-i energiamõjuga toodete direktiiv))

Tootel on CE-märgis:

Staphorst, 24-11-2017



M. Schouten
Managing Director

1 Energiamõju iseloomustavad väärtused

Toote Flair 325 (Plus) tehniliste andmete leht kooskõlas ökodisaini määrusega (energiamõjuga tooted) 1254/2014 (lisa I\V)					
Tootja:		**Brink Climate Systems B.V.**			
Mudel:		**Flair 325 (Plus)**			
Kliimatüüp	**Juhtimistüüp**	**Erienergiatarve (SEC), kWh/m^2/a**	**SEC klass**	**Aastane elektrikulu (AEC), kWh**	**Aastas säästetud soojusenergia, kWh**
Keskmine	käsitsi	-40.99	A	233	4560
	kellapõhine juhtimine	-41.59	A	224	4574
	1 anduriga (RV/CO_2/VOC)	-42.72	A+	205	4603
	2 või enama anduriga (RV/CO_2/VOC)	-44.71	A+	167	4659
Külm	käsitsi	-85.11	A+	770	6960
	kellapõhine juhtimine	-85.85	A+	761	6982
	1 anduriga (RV/CO_2/VOC)	-87.25	A+	742	7025
	2 või enama anduriga (RV/CO_2/VOC)	-89.79	A+	704	7112
Palav	käsitsi	-15.72	E	188	2400
	kellapõhine juhtimine	-16.24	E	179	2408
	1 anduriga (RV/CO_2/VOC)	-17.21	E	160	2422
	2 või enama anduriga (RV/CO_2/VOC)	-18.88	E	122	2452
Ventilatsiooniseadme tüüp:		Soojustagastusega tasakaalustatud elamuventilatsiooniseade			
Ventilaator:		EC – pidevalt juhitava kiirusega ventilaator			
Soojusvaheti tüüp:		Rekuperatiivne plastist rist-vastuvoolu soojusvaheti			
Soojuslik efektiivsus		91%			
Max vooluhulk:		325 m^3/h			
Max võimsus:		144,5 W			
Müravõimsustase Lwa:		41 dB(A)			
Etalonvooluhulk:		228 m^3/h			
Nimirõhk:		50 Pa			
Erivõimsus (SEL):		0,15 W/m^3/h			
Juhtimistegur:		1,0, kui kasutusel on pöördlüliti			
		0,95, kui juhtimine toimub kellaajapõhiselt			
		0,85, kui kasutusel on üks andur			
		0,65, kui kasutusel on vähemalt kaks andurit			
Leke*	Sisemine	2,85%			
	Välimine	2,85%			
Filtri puhastamise/asendamise näidu asukoht:		Seadme ekraanil / pöördlülitil (LED) / Brink Air Control. **Tähelepanu!** Optimaalse energiatõhususe ja töökindluse tagamiseks tuleb filtreid korrapäraselt kontrollida ning puhastada või asendada.			
Paigaldusjuhendi internetiaadress:		http://www.brinkclimatesystems.nl/nl/professionals			
Möödavool:		Jah, 100% möödavool			

* Mõõtmised on teinud TZWL kooskõlas standardiga EN 13141-7

Liigitus alates 1. jaanuarist 2016	
SEC klass (keskmine kliimatüüp)	SEC, kWh/m²/a
A+ (suurim energiatõhusus)	SEC < –42
A	–42 ≤ SEC < –34
B	–34 ≤ SEC < –26
C	–26 ≤ SEC < –23
D	–23 ≤ SEC < –20
E (kõige väiksem energiatõhusus)	–20 ≤ SEC < –10

EN 13141-7:2010 sertifikaate

KF.82.01.257.AD.01
18.05.18

TZWL

Declaration of confirmity regarding the determination of energetic efficiency according to EN 13141-7:2010

On behalf of Brink Climate Systems B.V. the determination of energetic efficiency was conducted by Europäisches Testzentrum für Wohnungslüftungsgeräte (TZWL) e. V. in Dortmund, Germany.

Tests were carried out according to:

- EN 13141-7:2010; Ventilation for buildings - Performance testing of components/products for residential ventilation - Part 7: Performance testing of a mechanical supply and exhaust ventilation units (including heat recovery) for mechanical ventilation systems intended for single family dwellings

Technical data of the tested unit:

Manufacturer:	Brink Climate Systems B.V.
Type:	Flair 325 4/0 L EU
Serial Number:	430000180301
Year of construction:	2018
Power supply:	230 V ~ 50 Hz
CE-Label:	Yes
Maximum volume flow:	325 m³/h

Results, energetic efficiency 7°C:

Air flow [m³/h]	Temperature ratio, supply air $\eta_{\theta,su}$ [%]	Total electric power consumption P_E [W]	Specific electric power consumption [W/m³/h]
51	98,4	11,7	0,23
224	90,8	34,7	0,15
325	90,5	79,2	0,24

Results, energetic efficiency 2°C:

Air flow [m³/h]	Temperature ratio, supply air $\eta_{\theta,su}$ [%]	Total electric power consumption P_E [W]	Specific electric power consumption [W/m³/h]
50	97,7	11,5	0,23
225	94,0	37,0	0,16
327	93,2	86,8	0,27

Results of performance tests of aerodynamic characteristics, of heat recovery characteristics and of the effective power consumption are taken from tests with number M.82.01.257.AD.

Passive House Certificate

CERTIFICATE

Certified Passive House Component

Component-ID 1288vs03 valid until 31st December 2019

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany



Category:	**Air handling unit with heat recovery**
Manufacturer:	**Brink Climate Systems B.V.** **Netherlands**
Product name:	**Brink Flair 325**
Specification:	Airflow rate < 600 m^3/h
Heat exchanger:	Recuperative

This certificate was awarded based on the product meeting the following main criteria

Heat recovery rate	η_{HR}	$\geq$	75 %
Specific electric power	$P_{el,spec}$	$\leq$	0.45 Wh/m^3
Leakage		<	3 %
Comfort	Supply air temperature $\geq$ 16.5 °C at outdoor air temperature −10 °C		

Airflow range
69–251 m^3/h
Heat recovery rate
η_{HR} = 91 %
Specific electric power
$P_{el,spec}$ = 0.21 Wh/m^3

At an airflow of 202 m^3/h, the specific electric power Pel,spec = 0.19 Wh/m^3.

cool, temperate climate
CERTIFIED COMPONENT
Passive House Institute

www.passivehouse.com

Brink Climate Systems B.V.
Wethouder Wassebaliestraat 8, 7951 SN Staphorst, Netherlands
☎ +31 (0)522 46 96 13 | ✉ info@brinkclimatesystems.nl | http://www.brinkclimatesystems.nl |

Passive House comfort criterion

At an outdoor air temperature of - 10 °C a supply air temperatur higher than 16.5 °C is achieved by use of an internal and additional external electric preheater. The criterion is therefore met.

Efficiency criterion (heat recovery rate)

The effective heat recovery rate is measured at a test facility using balanced mass flows of the outdoor and exhaust air. The boundary conditions for the measurement are documented in the testing procedure.

$$\eta_{HR} = \frac{(\theta_{ETA} - \theta_{EHA}) + \frac{P_{el}}{\dot{m} \cdot c_p}}{(\theta_{ETA} - \theta_{ODA})}$$

With

η_{HR}	Heat recovery rate in %
θ_{ETA}	Extract air temperature in °C
θ_{EHA}	Exhaust air temperature in °C
θ_{ODA}	Outdoor air temperature in °C
P_{el}	Electric power in W
$\dot{m}$	Mass flow in kg/h
c_p	Specific heat capacity in W h/(kg K)

Heat recovery rate
η_{HR} = 91 %

Efficiency criterion (electric power)

The overall electrical power consumption of the device is measured at the test facility at an external pressure of 100 Pa (50 Pa, respectively, for the intake and outlet). This includes the general electrical power consumption for operation and control but not for frost protection.

Specific electric power
$P_{el,spec}$ = 0.21 Wh/m^3

Efficiency ratio

The efficiency ratio provides information about the overall energy performance of the respective ventilation unit. It specifies the achieved reduction in ventilation heat losses by using a ventilation unit with heat recovery rather than without.

Efficiency ratio
ϵ_L = 0.76

2/4 Brink Flair 325

www.passivehouse.com

Leakage

The leakage airflow must not exceed 3 % of the average airflow of the unit's operating range.

Internal leakage	External leakage
2.49 %	0.88 %

Settings and airflow balance

It must be possible to adjust the balance of airflows at the unit itself (either between the exhaust and the outdoor airflows or between the supply and the extract airflows, if the unit is respectively placed inside or outside of the insulated thermal envelope of the building).

- This unit is certified for airflow rates of 69–251 m^3/h.
- Balancing the airflow rates of the unit is possible.
- The user should have at least all the following setting options:
  - ✓ Switching the system on and off.
  - ✓ Synchronized adjustment of the supply and extract airflows to basic ventilation (70–80 %), standard ventilation (100 %) and increased ventilation (130 %) with a clear indication of the current setting.
- The device has a standby power consumption of 3.90 W. The target value of 1 W was exceeded. The device should be equipped with an additional external switch so that it can be disconnected from the mains, if required.
- After a power failure, the device will automatically resume operation.

Acoustical testing

The required limit for the sound power level of the device is 35 dB(A) in order to limit the sound pressure level in the installation room. The sound level target value of less than 25 dB(A) in living spaces and less than 30 dB(A)in functional spaces must be ensured by installing commercial silencers.The following sound power levels are met at an airflow rate of 248 m^3/h:

Device	Duct			
	Outdoor	Supply air	Extract air	Exhaust air
44.5 dB(A)	48.5 dB(A)	60.5 dB(A)	49.0 dB(A)	59.0 dB(A)

- The unit does not fulfil the requirements for the sound power level. The unit must therefore be installed acoustically separated from living areas.
- One example of suitable silencers for supply and extract air ducts is mentioned in the detailed test report or can be obtained from the manufacturer. It is recommended to identify suitable silencers for each individual project.

Indoor air quality

This unit is equipped with following filter qualities by default:

Outdoor air filter	Extract air filter
ISO ePM1 50%	ISO Coarse 60%

On the outdoor air/ supply air side the filter quality class F7 is recommended. If not standard configuration, the F7 filter is available as accessory part.

Component-ID: 1288vs03 3/4

www.passivehouse.com

Frost protection

Appropriate measures should be taken to prevent the heat exchanger and optional downstream hydraulic heater coil from getting damaged by frost during extreme winter temperatures (−15 °C). It must be ensured that the unit's ventilation performance is not affected during frost protection cycles.

- Frost protection of the heat exchanger:
  - ✓ In order to protect the heat exchanger from freezing, the unit is equipped with an internal electric preheater with a power of 1000 W. In order to ensure the frost protection even at low outdoor air temperature, the unit can be optionaly equipped with an additional extrnal electric preheater with a power of 1000 W. The operation of this frost protection is controlled depending on the outdoor air temperature. The laboratory measurement has proved, that this frost protection at an upper airflow rate and an outdoor air temperature of -15 °C is sufficient. By the laboratory testing, the preheaters were first activated by an outdoor air temperature of -5.6 °C.
- Frost protection of downstream hydraulic heater coils:
  - ✓ In order to protect a downstream hydraulic heater coil, both fans are switched off in case the supply air temperature drops down to 5 °C.

4/4 Brink Flair 325

www.passivehouse.com

Vaata ka: Täielik passiivmaja sertifikaat