

SAP Appendix Q Testing Results
Central mechanical supply and exhaust ventilation system
packages with heat recovery used in a single dwelling

Brand Name		Brink
Model		Renovent Sky 300
Model Qualifier (if applicable)		
Current Manufacturer and Contact Details	Name	Brink Climate Systems B.V.
	Address	Postbus 11 NL-7950 AA Staphorst Holland
	Telephone	00 31 522 46 99 44
	Website	http://www.brinkclimatesystems.nl
Original Manufacturer (if different)		
First Year of Manufacture		2012
Last Year of Manufacture		
Testing Body		BRE
Date of test		13/09/2012
Serial Number of Product Tested		422004121601
MVHR to outside grille duct types and size		150 & 125mm diameter rigid plastic & 200mm rectangular rigid plastic
Duct types and sizes used for supply and exhaust		150 & 125mm diameter rigid plastic & 200mm rectangular rigid plastic

Results of leakage tests

Table Q1

Internal	Pass
External	Pass

Results for SAP calculations (at minimum flow rate condition)

This product has only been tested with rigid ductwork and the data are not applicable for SAP calculations if installed with flexible ductwork.

Table Q2 – Systems with rigid ductwork only

Exhaust terminal configuration	Fan speed setting	Specific fan power (W/l/s)	Heat exchange efficiency (%)	Energy Saving Trust Best Practice Performance Compliant
Kitchen + 1 additional wet room	Supply 18% Exhaust 21%	0.65	92	Yes
Kitchen + 2 additional wet rooms	Supply 25% Exhaust 26%	0.59	90	Yes
Kitchen + 3 additional wet rooms	Supply 31% Exhaust 32%	0.61	89	Yes
Kitchen + 4 additional wet rooms	Supply 36% Exhaust 37%	0.64	88	Yes
Kitchen + 5 additional wet rooms	Supply 41% Exhaust 42%	0.69	87	Yes
Kitchen + 6 additional wet rooms	Supply 46% Exhaust 48%	0.77	86	Yes
Kitchen + 7 additional wet rooms	Supply 52% Exhaust 55%	0.91	85	Yes

These figures are entered into either:

- (a) In the case of SAP software amended to SAP 2005 version 9.81 allowing direct entry of MVHR data, the SAP software, or
- (b) In the case of SAP software amended to SAP 2005 version 9.81 not allowing direct entry of MVHR data, the SAP Q MVHR Calculation Spreadsheet v9.81 and the results from the spreadsheet into the Special Features part of the SAP 9.81 software, or
- (c) In the case of SAP software to SAP 2005 version 9.80 , the SAP Q MVHR Calculation Spreadsheet v9.80 and the results from the spreadsheet into the Special Features part of the SAP 9.80 software. They must **NOT** be entered directly into SAP 2005 version 9.80 software

Table Q3 – Systems with flexible ductwork only

Exhaust terminal configuration	Fan speed setting	Specific fan power (W/l/s)	Heat exchange efficiency (%)	Energy Saving Trust Best Practice Performance Compliant
Kitchen + 1 additional wet room	N/A	N/A	N/A	N/A

Results for Approved Document F (at maximum flow rate condition)

Table Q4

Exhaust terminal configuration	Fan speed setting	Total supply flow rate (l/s)	Total exhaust flow rate (l/s)
Kitchen + 1 additional wet room	Supply 18% Exhaust 21%	15.0	15.3
Kitchen + 2 additional wet rooms	Supply 25% Exhaust 26%	21.0	21.5
Kitchen + 3 additional wet rooms	Supply 31% Exhaust 32%	27.0	27.6
Kitchen + 4 additional wet rooms	Supply 36% Exhaust 37%	33.0	33.8
Kitchen + 5 additional wet rooms	Supply 41% Exhaust 42%	39.0	40.0
Kitchen + 6 additional wet rooms	Supply 46% Exhaust 48%	45.0	46.0
Kitchen + 7 additional wet rooms	Supply 52% Exhaust 55%	51.0	52.5

Comments

Only figures from Table Q2 or Table Q3, not both, should be used with the SAP Q Calculation Spreadsheet for this technology type.

Table Q4 results are only applicable for Approved Document F requirements.